



City of Rockwall

*The New Horizon*

**ADDENDUM #1  
TO THE INVITATION FOR BID PACKET FOR**

**NEW CONCRETE PAVEMENT  
SERVICE CENTER PARKING LOT**

The addendum is an integral part of the Invitation for Bid #2022-4 and must be signed and returned with the Bid submittal or acknowledged in the submittal packet.

The purpose of this addendum is to incorporate the following changes and or clarifications to the bid packet:

1. Alternative Subgrade Prep – Excavate 4500 SY at 8 inches and Prepare Subgrade in lieu of “Prepare Subgrade Pulverize HMAC and Base 4500 SY” for existing asphalt and base rock mixed into the subgrade and then excavated to grade.
2. Will Contractor be able to work in all locations simultaneously?  
Work shall be done in 2 phases. Work in area 2 shall be divided into 2 pieces; the western third can be constructed simultaneously with section 3 since gate access will be interrupted with section 3 construction. Area 1 can be completed anytime. The eastern section of area 2 shall be constructed either before or after area 3 and the western section of area 2 work. Areas marked in attachment.

All other terms and conditions remain unchanged. If you have any questions regarding this addendum, please contact me at [lewing@rockwall.com](mailto:lewing@rockwall.com) or 972-772-6418.

Respectfully,

Lea Ann Ewing  
Purchasing Agent  
6-10-2022